Map ID MAP FINDINGS

Direction Distance

Distance Elevation Site EDR ID Number

Database(s) EPA ID Number

AZ256 IFO NY Spills S116552975 SSE 2954 WEST 8TH ST N/A

SSE 2954 WEST 8TH ST 1/4-1/2 BROOKLYN, NY

0.378 mi.

1995 ft. Site 1 of 4 in cluster AZ

Relative: SPILLS: Higher Name: IFO

 Actual:
 Address:
 2954 WEST 8TH ST

 3 ft.
 City,State,Zip:
 BROOKLYN, NY

 Spill Number/Closed Date:
 1311044 / 2014-05-08

 Facility ID:
 1311044

 Facility Type:
 ER

 DER Facility ID:
 449539

 Site ID:
 491926

 DEC Region:
 2

Spill Cause: Equipment Failure

Spill Class: Α4 2401 SWIS: Spill Date: 2014-02-23 Investigator: **RWAUSTIN** Referred To: Not reported Reported to Dept: 2014-02-23 CID: Not reported Water Affected: Not reported

Spill Source: Commercial/Industrial

Spill Notifier: Other
Cleanup Ceased: Not reported
Cleanup Meets Std: False
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0

Date Entered In Computer: 2014-02-23
Spill Record Last Update: 2014-05-08
Spiller Name: Not reported
Spiller Company: CON ED
Spiller Address: Not reported
Spiller Company: 999
Contact Name: ERT

DEC Memo: "EMIS 233045 5/8/14 - Austin - Transformer fire in vault led to the discovery of 3 gals oil atop 300 gals water in affected vault - Con

Ed contained and cleaned up the spill; transformer found to be not leaking - See files in D2 for further information - Spill closed -

end"

Remarks: "cleanup pending"

All Materials:

491926 Site ID: Operable Unit ID: 1241467 Operable Unit: 01 2241878 Material ID: Material Code: 0541A Material Name: dielectric fluid Case No .: Not reported Material FA: Petroleum Quantity: 1.00 Units:

Recovered: Not reported Oxygenate: Not reported